

# Drinking Water Systems Regulation O. Reg. 170/03 Annual Report

Drinking Water System Number: 260097058  
 Drinking Water System Name: Calabogie Peaks Resort  
 Drinking Water System Owner: Paul Murphy  
 Drinking Water System Category: Non Municipal Year Round Residential  
 Period being reported: 2024

<b><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></b>	<b><u>Complete for all other Categories</u></b>
<p>Does your Drinking Water System serve more than 10,000 people? Yes ( ) No ( )</p> <p>Is your annual report available to the public at no charge on a website on the internet? Yes ( ) No ( )</p> <p>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</p> <p>_____</p> <p>_____</p> <p>_____</p> <p>_____</p> <p>_____</p>	<p>Number of Designated Facilities served: <u>0</u></p> <p>Did you provide a copy of your annual report to all Designated Facilities you serve? Yes ( ) No ( )</p> <p>Number of Interested Authorities you report to: <u>0</u></p> <p>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility? Yes ( ) No ( )</p>

List all Drinking Water Systems (if any), which receive all of their drinking water from your system:

Drinking Water System Name	Drinking Water System Number

Did you provide a copy of your annual report to all Drinking Water System owners that are connected to you and to whom you provide all of its drinking water?  
Yes ( ) No ( )

Indicate how you notified system users that your annual report is available, and is free of charge.

- ( ) Public access/notice via the web
- ( ) Public access/notice via Government Office
- ( ) Public access/notice via newspaper
- (x) Public access/notice via Public Request
- ( ) Public access/notice via Public Library
- ( ) Public access/notice via other method:

# Drinking Water Systems Regulation O. Reg. 170/03 Annual Report

**Describe your Drinking Water System**

2 Drilled Wells, Water Softener, Iron filter & Chlorine injection as primary and secondary disinfection.

**List all water treatment chemicals used over this reporting period**

Water Softener Salt, chlorine

**Were any significant expenses incurred to?**

- ( ) Install required equipment
- ( ) Repair required equipment
- ( ) Replace required equipment

**Please provide a brief description and a breakdown of monetary expenses incurred**

**Provide details on the notices submitted in accordance with subsection 18 (1) of the Safe Drinking Water Act or section 16-4 of Schedule 16 of O.Reg. 170/03 and reported to Spills Action Center**

Incident Date	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date

**Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period**

	# of Samples	Range of E.Coli or Fecal Results (min-max)	Range of Total Coliform Results (min-max)	Number of HPC Samples	Range of HPC Results (min-max)
Raw	13	0-0	0 - 0	n/a	n/a
Treated	4	n/a	n/a	n/a	n/a
Distribution	26	0-0	0-0	26	0-230

# Drinking Water Systems Regulation O. Reg. 170/03 Annual Report

Operational testing done under Schedule 7, 8 or 9 of Regulation 170/03 during the period covered by this Annual Report.

**NOTE:** For continuous monitors use 8760 as the number of samples

	# of Samples	Range of Results (min-max)
<b>Turbidity</b>	<b>13</b>	<b>0.06-0.89 NTU</b>
<b>Chlorine</b>	<b>365</b>	<b>0.23-2.01 WTP 0.15-1.81 Distribution</b>
<b>Fluoride</b> (If the DWS provides fluoridation)	<b>n/a</b>	<b>n/a</b>

**NOTE:** Record the unit of measure if it is *not* milligrams per litre.

Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of measure

Summary of Inorganic Parameters tested during this reporting period or the most recent sample results

Parameter	Sample Date	Result Value	Unit of measure	Exceedence
<b>Antimony Sb</b>	<b>Sep 1, 2020</b>	<b>&lt;0.0005</b>	<b>mg/l</b>	<b>No</b>
<b>Arsenic As</b>	<b>Sep 1, 2020</b>	<b>&lt;0.001</b>	<b>mg/l</b>	<b>No</b>
<b>Barium Ba</b>	<b>Sep 1, 2020</b>	<b>&lt;0.01</b>	<b>mg/l</b>	<b>No</b>
<b>Boron B</b>	<b>Sep 1, 2020</b>	<b>0.01</b>	<b>mg/l</b>	<b>No</b>
<b>Cadmium Cd</b>	<b>Sep 1, 2020</b>	<b>&lt;0.0001</b>	<b>mg/l</b>	<b>No</b>
<b>Chromium Cr</b>	<b>Sep 1, 2020</b>	<b>&lt;0.001</b>	<b>mg/l</b>	<b>No</b>

# Drinking Water Systems Regulation O. Reg. 170/03 Annual Report

Lead	Mar 22, 2021	<0.001	mg/l	No
Lead	Mar 22, 2021	<0.001	mg/l	No
Lead	Mar 22, 2021	<0.001	mg/l	No
Lead	Mar 22, 2021	<0.001	mg/l	No
Lead	Mar 22, 2021	<0.001	mg/l	No
Lead	Mar 22, 2021	0.003	mg/l	No
Lead	Mar 22, 2021	<0.001	mg/l	No
Mercury Hg	Sep 1, 2020	<0.0001	mg/l	No
Selenium Se	Sep 1, 2020	<0.001	mg/l	No
Sodium Na	Sep 1, 2020	72	mg/l	Yes
Uranium U	Sep 1, 2020	0.004	mg/l	No
Fluoride F	Sep 1, 2020	>0.10	mg/l	No
Nitrite	Oct 3, 2024	< 0.1	mg/l	No
Nitrate	Oct 3, 2024	1.18	mg/l	No
THM(RAA)	2024	46.9	µg/l	No
HAA(RAA)	2024	13.6	µg/l	No

<p><b>Lead Sampling Status: EXEMPT</b>  <b>Next Sampling Date:</b></p>
--

**Summary of Organic Parameters sampled during this reporting period or the most recent sample results**

Parameter	Sample Date	Result Value	Unit of measure	Exceedence
Alachlor	Sep 1, 2020	<0.5	µg/l	No
Atrazine + Metabolites	Sep 1, 2020	<1.0	µg/l	No
Azinphos-methyl	Sep 1, 2020	<2.0	µg/l	No

# Drinking Water Systems Regulation O. Reg. 170/03

## Annual Report

Benzo(a)pyrene	Sep 1, 2020	<0.01	µg/l	No
Bromoxynil	Sep 1, 2020	<0.5	µg/l	No
Carbaryl	Sep 1, 2020	<5.0	µg/l	No
Carbofuran	Sep 1, 2020	<5.0	µg/l	No
Chlorpyrifos	Sep 1, 2020	<1.0	µg/l	No
Diazinon	Sep 1, 2020	<1.0	µg/l	No
Dicamba	Sep 1, 2020	<1.0	µg/l	No
Dichlorophenol, 2, 4-	Sep 1, 2020	<0.2	µg/l	No
Dichlorophenoxy acetic acid, 2, 4- (2, 4-D)	Sep 1, 2020	<1.0	µg/l	No
Diclofop-methyl	Sep 1, 2020	<0.9	µg/l	No
Dimethoate	Sep 1, 2020	<2.5	µg/l	No
Diuron	Sep 1, 2020	<5	µg/l	No
Malathion	Sep 1, 2020	<0.5	µg/l	No
Metolachlor	Sep 1, 2020	<1.0	µg/l	No
Metribuzin	Sep 1, 2020	<5.0	µg/l	No
Pentachlorophenol	Sep 1, 2020	<1.0	µg/l	No
Phorate	Sep 1, 2020	<0.5	µg/l	No
Picloram	Sep 1, 2020	<5.0	µg/l	No
Prometryne	Sep 1, 2020	<0.25	µg/l	No
Simazine	Sep 1, 2020	<1.0	µg/l	No
Terbufos	Sep 1, 2020	<0.4	µg/l	No
Tetrachlorophenol 2, 3, 4, 6-	Sep 1, 2020	<1.0	µg/l	No
Triallate	Sep 1, 2020	<1.0	µg/l	No
Trichlorophenol 2, 4, 6-	Sep 1, 2020	<1.0	µg/l	No
Trifluralin	Sep 1, 2020	<1.0	µg/l	No

# Drinking Water Systems Regulation O. Reg. 170/03

## Annual Report

<b>Poly-Chlorinated Bi phenyls (PCB's)</b>	<b>Sep 1, 2020</b>	<b>&lt;0.1</b>	<b>µg/l</b>	<b>No</b>
<b>Diquat</b>	<b>Sep 1, 2020</b>	<b>&lt;5</b>	<b>µg/l</b>	<b>No</b>
<b>Paraquat</b>	<b>Sep 1, 2020</b>	<b>&lt;1</b>	<b>µg/l</b>	<b>No</b>
<b>Glyphosate</b>	<b>Sep 1, 2020</b>	<b>&lt;25</b>	<b>µg/l</b>	<b>No</b>
<b>Benzene</b>	<b>Sep 1, 2020</b>	<b>&lt;0.5</b>	<b>µg/l</b>	<b>No</b>
<b>Carbon Tetrachloride</b>	<b>Sep 1, 2020</b>	<b>&lt;0.2</b>	<b>µg/l</b>	<b>No</b>
<b>Dichlorobenzene 1, 2-</b>	<b>Sep 1, 2020</b>	<b>&lt;0.4</b>	<b>µg/l</b>	<b>No</b>
<b>Dichlorobenzene 1, 4-</b>	<b>Sep 1, 2020</b>	<b>&lt;0.4</b>	<b>µg/l</b>	<b>No</b>
<b>Dichloroethane 1, 2-</b>	<b>Sep 1, 2020</b>	<b>&lt;0.2</b>	<b>µg/l</b>	<b>No</b>
<b>Dichloroethene 1, 1-</b>	<b>Sep 1, 2020</b>	<b>&lt;0.5</b>	<b>µg/l</b>	<b>No</b>
<b>Dichloromethane (Methylene Chloride)</b>	<b>Sep 1, 2020</b>	<b>&lt;4.0</b>	<b>µg/l</b>	<b>No</b>
<b>Monochlorobenzene (Chlorobenzene)</b>	<b>Sep 1, 2020</b>	<b>&lt;0.5</b>	<b>µg/l</b>	<b>No</b>
<b>Tetrachloroethylene</b>	<b>Sep 1, 2020</b>	<b>&lt;0.3</b>	<b>µg/l</b>	<b>No</b>
<b>Trichloroethylene</b>	<b>Sep 1, 2020</b>	<b>&lt;0.3</b>	<b>µg/l</b>	<b>No</b>
<b>Vinyl Chloride</b>	<b>Sep 1, 2020</b>	<b>&lt;0.2</b>	<b>µg/l</b>	<b>No</b>
<b>1,2-dichloroethane-d4</b>	<b>Sep 1, 2020</b>	<b>113</b>	<b>%</b>	<b>No</b>
<b>4-bromofluorobenzene</b>	<b>Sep 1, 2020</b>	<b>83</b>	<b>%</b>	<b>No</b>
<b>Toluene-d8</b>	<b>Sep 1, 2020</b>	<b>94</b>	<b>%</b>	<b>No</b>
<b>MCPA</b>	<b>Sep 1, 2020</b>	<b>&lt;10</b>	<b>µg/l</b>	<b>No</b>
<b>THM (NOTE: show latest annual average)</b>	<b>2024</b>	<b>46.9</b>	<b>µg/l</b>	<b>No</b>
<b>HAA(NOTE: show latest annual average)</b>	<b>2024</b>	<b>13.6</b>	<b>µg/l</b>	<b>No</b>

# Drinking Water Systems Regulation O. Reg. 170/03 Annual Report

List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.

Parameter	Result Value	Unit of Measure	Date of Sample
Sodium	72	mg/L	Sep 25, 2020
Sodium	116	mg/L	Oct 8, 2020